subject to aproval of Uttar Pradesh State Electricity Board (UPSEB), development activities in the villages, increase in reservation for land oustees for shops in the township etc. In turn, the land oustees will allow uninterrupted work for completion of the balance work like ash handling etc.

Performance of Power Stations

1045. SHRI V. RAJAN CHELLAPPA: Will the Minister of POWER be pleased to state:

(a) the details of the performance of the power stations for the last three years, State-wise;

(b) whether the performance of existing power stations is satisfactory; and

(c) if so, the details thereof?

THE MINISTER OF STATE IN THE MINISTRY OF POWER (SHRI P. V. RANGAYYA NAIDU (a) to (c) Station-wise|State-wise details of Plant Load Factor Thermal Power Stations in the country during 1991-92 to 1993-94 are given in Annexure Statement (See below) Generation from Hydro and Gas station depends upon the availability of water, gas and the system load conditions.

Performance of thermal power stations depend upon the age of the unit, availability of requisite quantity and quality of coal, maintenance practices, system load conditions, hydro-thermal mis in the state/region and transmission constraints.

Statement

The state-wise/system-wise/station-wise plant load factor of thermal power stations during 1991-92 *to* 1993-94

Name of the State/System/Station	Plant Load Factor (%)		
	1991-92	1992-93	1993-94
1	2	3	4
Delhi :			
Indraprastha	60.8	57.1	47.2
Rajghat	49.5	47.8	52.5
DESU	57.11	54.0	49.0
Badarpur	64.2	74.1	71.9
Delhi	61.5	65.7	63.4
Haryana :			
Faridabad Ext'n.	56.6	61.9	51.1
Panipat	43.2	46.9	37.5
HSEB	45.9	49.9	40.3
Rajasthan			
Kota	66.3	76.9	81.1
RSEB	66.3	76.9	81.1

1	2	3	4
Punjab			
Bhatinda	49.8	59.8	70.7
Ropar	54.5	57.9	60.6
Punjab	52.8	58.5	63.5
Uttar Pradesh :			
Obra	50.6	55.6	51.0
Panki	15.6	26.8	34.6
Harduaganj 'A'	..	..	..
Harduaganj 'B' & 'C'	21.3	26.9	29.7
Paricha	29.5	33.0	39.0
Anpara	72.0	74.5	75.8
Tanda	23.3	31.6	30.6
UPSEB	44.4	50.5	50.1
National Thermal Power Station (Singrauli)	77.9	75.2	81.5
Rihand	74.2	73.9	78.0
Dadri	..	..	73.1
NTPC Unchahar	.	55.0	68.8
Uttar Pradesh	59.1	61.9	65.4
Gujarat :			
Dhuvaran	63.6	58.4	50.6
Ukai	57.4	58.2	56.0
Gandhi Nagar	63.5	69.5	68.1
Wanakbori	52.7	63.0	64.8
Sikka	53.5	61.5	54.6
Kutch Lign	47.5	45.5	54.5
GEB	57.0	61.6	60.4
A.E. Company	49.7	35.0	38.4
Sabarmati	69.5	66.1	70.8
Gujarat Pvt.	67.2	62.5	67.0
Gujarat	58.0	61.7	61.0

1	2	3	4
Maharashtra :			
Nasik	60.6	62.7	63.4
Koradi	63.7	64.2	66.1
Paras	61.9	50.9	51.4
Bhusawal	65.1	71.2	60.8
Parli	42.5	36.4	52.5
Chandrapur	68.9	62.4	67.3
K. Khada	68.0	63.1	77.3
MSEB	61.3	59.7	64.1
Trombay	53.8	54.3	48.8
Maharashtra	59.4	58.5	60.7
Madhya Pradesh :			
Satpura	43.6	46.4	50.7
Korba	41.6	45.5	49.8
Amarkantak	40.6	48.7	53.6
Korba West	63.2	65.6	67.2
MPEB	49.4	52.5	56.0
NTPC Korba	70.8	70.3	77.8
NTPC Vindhyachal	69.5	57.1	75.2
Madhya Pradesh	60.7	59.7	67.7
Andhra Pradesh :			
Kothagudam	50.5	53.4	55.6
Vijayawada	72.5	77.0	80.3
Ramagundam B	56.5	39.8	65.9
Nellore	45.2	39.6	42.6
APSEB	62.1	65.0	68.7
NTPC Ramagundam	61.4	67.3	79.3
Andhra Pradesh	61.7	66.3	74.7
Karnataka :			
Raichur	59.1	49.4	66.9
HPCL	..	..	..
Tamil Nadu :			
Ennore	47.6	52.0	47.1
Tuticorin	70.1	76.0	78.8

1	2	3	4
Mettur	48.5	64.2	76.4
TNEB	55.4	65.2	69.1
Neyveli	66.8	56.5	55.5
Tamil Nadu	60.1	61.2	62.6
Bihar			
Patratu	19.7	27.9	27.5
Barauni	19.6	21.3	18.4
Muzaffarpur	28.8	20.5	21.9
Bihar	21.3	25.2	24.4
Orissa			
Talchar	30.2	34.5	35.6
IB Valley	..	..	..
West Bengal			
Bandel	44.0	27.1	48.3
Santaldih	15.9	35.5	31.8
WBSEB	30.7	31.1	40.5
Kolaghat (WBP. Dv. C)	61.1	53.1	68.2
Durgapur Project Ltd.	17.3	28.9	26.3
Calcutta Electric Supply Company	58.3	67.5	71.3
NTPC Farakka	63.6	67.0	64.6
West Bengal	46.0	40.9	55.0
Damodar Valley Corporation :			
Chandrapur	9.7	29.5	34.4
Durgapur	34.1	27.7	53.6
Bokaro	40.5	38.5	46.0
Damodar Valley Corporation	.. 33.6	.. ..	.. 42.3
Assam			
Chandrapur	45.5	25.1	20.0
Namrup	28.6	30.5	23.8
Bongaigaon	18.9	21.8	14.8
Gas Turbine	20.4	21.3	28.3
Assam	24.7	24.3	19.9
ALL INDIA	55.3	57.1	61.